

BROC, LLC – 2025 Bleacher Inspection & ADA Compliance Checklist

brocllc.com | Parts & Service (720) 764-2335

Venue: _____ Date: _____ Inspector: _____

Item	OK/Repair	Notes
- Structural fasteners (bolts, anchors, welds) secure and intact	<input type="checkbox"/>	<input type="text"/>
- Guardrail openings ≤ 4 inches; gap protection in place	<input type="checkbox"/>	<input type="text"/>
- Aisle handrails secure and continuous	<input type="checkbox"/>	<input type="text"/>
- Seat boards/planks free of cracks or splinters	<input type="checkbox"/>	<input type="text"/>
- Decking surfaces level; no rust or soft spots	<input type="checkbox"/>	<input type="text"/>
- Power motor units operate smoothly; limit switches verified	<input type="checkbox"/>	<input type="text"/>
- Drive rollers/tubes aligned and lubricated	<input type="checkbox"/>	<input type="text"/>
- Floor anchors engage fully at maximum extension	<input type="checkbox"/>	<input type="text"/>
- Understructure free of debris and obstructions	<input type="checkbox"/>	<input type="text"/>
- End closures and safety curtains functional	<input type="checkbox"/>	<input type="text"/>
- Wheelchair bays clear; dimensions meet ADA	<input type="checkbox"/>	<input type="text"/>
- Companion seats installed adjacent to bays	<input type="checkbox"/>	<input type="text"/>
- Row and seat numbers legible	<input type="checkbox"/>	<input type="text"/>
- Warning signage posted and readable	<input type="checkbox"/>	<input type="text"/>
- Electrical cords/wiring undamaged	<input type="checkbox"/>	<input type="text"/>
- Emergency stop controls operational	<input type="checkbox"/>	<input type="text"/>
- Sharp edges/projections eliminated	<input type="checkbox"/>	<input type="text"/>
- Bleacher displacement within manufacturer tolerance	<input type="checkbox"/>	<input type="text"/>
- Inspection date, inspector name, corrective actions logged	<input type="checkbox"/>	<input type="text"/>